



NOTES:

1. EXTENSIONS SHALL BE 6" ASTM D 3034 SDR 35 PVC PIPE (ONE PIECE)
2. VALVE BOX SHALL BE U.S. FILTER/PACIFIC WATER WORKS NO. 910 OR EQUAL.
3. THERE SHALL BE 1/2" CLEARANCE UNDER THE PIN CAST INTO THE LID.
4. THE OPERATOR NUT SHALL HAVE A DEPTH FROM 18"-30" FROM FINISH GRADE TO THE OPERATOR NUT.

STANDARD VALVE BOX AND COVER

PLAN #



CITY OF BATTLE GROUND
APPROVED

Phil W

CITY ENGINEER

4/16/07

DATE

| REVISIONS: | DATE: | DRAWN: | DESIGNED: |
|------------|---------|--------|-----------|
| 1 | 8/12/98 | BSG | GGH |
| 2 | 4/16/07 | JMH | MCH |
| | | | |
| | | | |

WA-3.1