

TABLE "A"


MAIN DIAMETER	BLOW-OFF DIAMETER
<12"	2" MINIMUM
≥12"	4" MINIMUM

NOTES:

1. BLOWOFFS SHALL BE INSTALLED 1' FROM THE END OF THE MAIN.
2. (5/8-) GRAVEL SHALL BE USED AS BEDDING AROUND THE SERVICE.
3. ALL PIPING UPSTREAM OF THE 2" GATE VALVE SHALL BE TYPE K COPPER OR BRASS

STANDARD BLOWOFF ASSEMBLY

PLAN #



CITY OF BATTLE GROUND
APPROVED

[Signature]
CITY ENGINEER

9/24/07
DATE

REVISIONS:	DATE:	DRAWN:	DESIGNED:
1	4/16/07	JMH	MCH
2	9/24/07	MCH	MCH

WA-4.2