



NOTES:

1. ALL METERS SHALL BE INSTALLED BY THE CITY OF BATTLE GROUND.
2. PRIOR TO CITY INSTALLATION OF METERS, ALL SERVICE APPLICATIONS MUST BE COMPLETED AND APPROVED. SERVICE FEES PAID IN FULL AND AS-BUILTS SUBMITTED AND APPROVED.
3. CONTRACTOR SHALL CONTACT CITY ENGINEERING DIVISION AT (360) 342-5071, 48 HOURS PRIOR TO INSTALLING ANY WATER SERVICE CONNECTIONS.
4. METERS WILL NOT BE SET BY THE CITY PRIOR TO DISINFECTION OF THE MAIN AND SERVICE, AND PRIOR TO A SUCCESSFUL BACTERIOLOGICAL TEST.
5. WATER SERVICES SHALL BE PRESSURE TESTED ALONG WITH THE MAIN.
6. DURING THE PRESSURE TEST, THE MAIN SHALL BE OPEN FOR INSPECTION OF ALL CORPORATION STOPS.
7. USE 1-7/8" BIT FOR ALL 2" SADDLE TAPS AND 1-3/8" BIT FOR 1-1/2" SADDLE TAPS.
8. METER BOX IS NOT ALLOWED IN HARD SURFACED AREAS WITHOUT PRIOR WRITTEN APPROVAL. METER BOX SHALL BE SLIGHTLY HIGHER (1/8" MAX.) THAN SURROUNDING GRADE AND MADE TO DRAIN AWAY FROM BOX.
9. BROOKS 65 METER BOX AND EXTENSION MAY BE ALLOWED WITH 1-1/2" METER SETS ONLY.

1-1/2" & 2" WATER SERVICE

PLAN #



CITY OF BATTLE GROUND APPROVED

Handwritten signature

8/22/07

CITY ENGINEER

DATE

REVISIONS:	DATE:	DRAWN:	DESIGNED:
1	8/12/98	BSG	GGH
2	4/16/07	JMH	MCH
3	8/7/07	MCH	MCH

WA-2.1