



SEE NOTE #2

NOTES:

1. EXTENSIONS SHALL BE 6" ASTM D 3034 SDR 35 PVC PIPE (ONE PIECE)
2. VALVE BOX SHALL BE U.S. FILTER/PACIFIC WATER WORKS NO. 910 OR EQUAL.
3. THERE SHALL BE 1/2" CLEARANCE UNDER THE PIN CAST INTO THE LID.
4. THE OPERATOR NUT SHALL HAVE A DEPTH FROM 18"-30" FROM FINISH GRADE TO THE OPERATOR NUT.

STANDARD VALVE BOX AND COVER

PLAN #



CITY OF BATTLE GROUND  
APPROVED

CITY ENGINEER

DATE

REVISIONS:	DATE:	DRAWN:	DESIGNED:
1	8/12/98	BSG	GGH
2	4/16/07	JMH	MCH

WA-3.1

*Handwritten signature*

*Handwritten date: 4/16/07*